

December 14, 2021

Dear Brigantine School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Brigantine Community School tested our school's drinking water for lead.

In accordance with the Department of Education regulations, Brigantine Community School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Brigantine Community School. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 110 samples taken, all but four (4) tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action Brigantine Community School has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
Room 312 ID #49-BM-E1(312)-S	15.7 ppb	Disconnected outlet and discontinued use. Posted signage "DO NOT DRINK- SAFE FOR HANDWASHING ONLY".
Room 313 ID #46-BM-D14(313)-S	20.9 ppb	
Room 404 ID #45-BM-D9(404)-S	27.5 ppb	
Room 406 ID # 2-BM-D7(406)-S	46.6 ppb	

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At very high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.


For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at www.brigantineschools.org. For more information about water quality in our schools, contact Mike Fulmor at the Brigantine Community School (609-266-3632).

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

A handwritten signature in black ink, appearing to read 'Glenn Robbins', written in a cursive style.

Glenn Robbins
Superintendent of Schools/Principal



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Marylee Morinelli
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

12/13/2021

Phone: (609) 820-9312

Fax: (609) 561-6197

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/22/2021. The results are tabulated on the attached data pages for the following client designated project:

Brigantine Community School Lead in Water Testing

The reference number for these samples is EMSL Order #012113390. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

Report amended 12/13/2021 16:28:09 Replaces initial report from 12/01/2021 14:34:13 Report was merged with Order ID 012113432 per client request, and project name revised to Brigantine Community School Lead in Water Testing.

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantine Community School Lead In Water Testing**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
1-BE-POE		11/20/2021 8:15:00 AM		012113390-0001			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	9.11	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:10
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
2-BE-162(146)-S		11/20/2021 8:17:00 AM		012113390-0002			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.05	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:21
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
3-BE-146(153)-S		11/20/2021 8:20:00 AM		012113390-0003			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:22
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
3N-BE-146(153)-IM		11/20/2021 8:23:00 AM		012113390-0004			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/24/2021	IC	11/26/2021	JW 17:05
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
5-BE-GYMR-BF		11/20/2021 8:25:00 AM		012113390-0005			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:24

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantine Community School Lead In Water Testing**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
7-BE-137(144)-S		11/20/2021 8:30:00 AM		012113390-0006			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.24	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:25
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
10-BE-134(138)-S		11/20/2021 8:35:00 AM		012113390-0007			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.77	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:26
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
11-BE-134(138)R-S		11/20/2021 8:40:00 AM		012113390-0008			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.55	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:28
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
12-BE-134(138)L-S		11/20/2021 8:45:00 AM		012113390-0009			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.03	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:32
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
12A-BE-HALL138R-DF		11/20/2021 8:32:00 AM		012113390-0010			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:34

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: Brigantine Community School Lead in Water Testing

Analytical Results

Client Sample Description 12B-BE-HALL138L-DF *Collected:* 11/20/2021 8:34:00 AM *Lab ID:* 012113390-0011

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:35

Client Sample Description 13-BE-PRIN-S *Collected:* 11/20/2021 8:50:00 AM *Lab ID:* 012113390-0012

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:37

Client Sample Description 14-BE-131(134)-S *Collected:* 11/20/2021 8:55:00 AM *Lab ID:* 012113390-0013

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	5.53	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:41

Client Sample Description 15-BE-101-S *Collected:* 11/20/2021 9:00:00 AM *Lab ID:* 012113390-0014

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:43

Client Sample Description 16-BE-102-S *Collected:* 11/20/2021 9:03:00 AM *Lab ID:* 012113390-0015

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 01:44

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli** Phone: (609) 820-9312
Coastal Environmental Compliance, LLC Fax: (609) 561-6197
PO Box 167 Received: 11/22/2021 09:00 AM
Hammonton, NJ 08037-0167

Project: **Brigantine Community School Lead in Water Testing**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
17-BE-103-S		11/20/2021 9:05:00 AM		012113390-0016	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 01:46
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
18-BE-104-S		11/20/2021 9:05:00 AM		012113390-0017	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.77	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 01:50
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
19-BE-105-S		11/20/2021 9:07:00 AM		012113390-0018	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 01:51
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
20-BE-106-S		11/20/2021 9:10:00 AM		012113390-0019	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.21	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 01:53
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
21-BE-107-S		11/20/2021 9:13:00 AM		012113390-0020	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 01:54

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantine Community School Lead in Water Testing**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
23-BE-110L-BF		11/20/2021 9:15:00 AM		012113390-0021			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 02:00
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
24-BE-127(129)-S		11/20/2021 9:18:00 AM		012113390-0022			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 02:08
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
25-BE-112-S		11/20/2021 9:20:00 AM		012113390-0023			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 02:09
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
26-BE-129(131)-S		11/20/2021 9:23:00 AM		012113390-0024			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 02:11
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
27-BE-113-S		11/20/2021 9:25:00 AM		012113390-0025			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.30	1.00 µg/L	11/23/2021	KB	11/24/2021	KB 02:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantline Community School Lead in Water Testing**

Analytical Results

Client Sample Description 28-BE-114-S *Collected:* 11/20/2021 9:27:00 AM *Lab ID:* 012113390-0026

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB
						02:14	

Client Sample Description 29-BE-115-S *Collected:* 11/20/2021 9:30:00 AM *Lab ID:* 012113390-0027

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB
						02:15	

Client Sample Description 30-BE-116-S *Collected:* 11/20/2021 9:33:00 AM *Lab ID:* 012113390-0028

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/23/2021	KB	11/24/2021	KB
						02:16	

Client Sample Description 31-BE-117-S *Collected:* 11/20/2021 9:35:00 AM *Lab ID:* 012113390-0029

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.77	1.00 µg/L	11/23/2021	KB	11/24/2021	KB
						02:18	

Client Sample Description 32-BE-118-S *Collected:* 11/20/2021 9:38:00 AM *Lab ID:* 012113390-0030

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	2.33	1.00 µg/L	11/23/2021	KB	11/24/2021	KB
						02:19	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantline Community School Lead in Water Testing**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
33-BE-119-S		11/20/2021 9:40:00 AM	012113390-0031		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 02:21
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
35-BE-119R-BF		11/20/2021 9:42:00 AM	012113390-0032		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 02:28
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
36-BE-120-S		11/20/2021 9:45:00 AM	012113390-0033		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.57	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 02:30
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
37-BE-121-S		11/20/2021 9:47:00 AM	012113390-0034		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	5.11	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 02:31
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
39-BE-HALL241L-BF		11/20/2021 9:50:00 AM	012113390-0035		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.44	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 12:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantine Community School Lead in Water Testing**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
40-BE-244(252)-S		11/20/2021 9:52:00 AM		012113390-0036	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 02:34
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
41-BE-245(253)-S		11/20/2021 9:53:00 AM		012113390-0037	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 02:36
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
42-BE-247(255)-S		11/20/2021 9:55:00 AM		012113390-0038	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 02:37
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
43-BE-248(256)-S		11/20/2021 10:00:00 AM		012113390-0039	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 02:38
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
44-BE-234-S		11/20/2021 10:03:00 AM		012113390-0040	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	13.4	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 02:43

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantine Community School Lead in Water Testing**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
45-BE-249(257)-S		11/20/2021 10:05:00 AM		012113390-0041	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 00:39
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
46-BE-250(258)-S		11/20/2021 10:07:00 AM		012113390-0042	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 00:44
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
47-BE-201-DF		11/20/2021 10:10:00 AM		012113390-0043	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	4.28	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 00:45
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
48-BE-214(216)-S		11/20/2021 10:21:00 AM		012113390-0044	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 00:47
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
49-BE-202(204)-S		11/20/2021 10:15:00 AM		012113390-0045	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.32	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 00:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli** Phone: (609) 820-9312
Coastal Environmental Compliance, LLC Fax: (609) 561-6197
PO Box 167 Received: 11/22/2021 09:00 AM
Hammonton, NJ 08037-0167

Project: **Brigantine Community School Lead in Water Testing**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
50-BE-203(205)-S		11/20/2021 10:17:00 AM		012113390-0046	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 00:50
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
51-BE-206(208)-S		11/20/2021 10:20:00 AM		012113390-0047	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 00:51
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
52-BE-207(209)-S		11/20/2021 10:21:00 AM		012113390-0048	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.25	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 00:53
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
53-BE-209(211)-S		11/20/2021 10:25:00 AM		012113390-0049	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.26	1.00 µg/L	11/24/2021 IC	11/26/2021 JW 14:49
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
54-BE-208(210)-S		11/20/2021 10:27:00 AM		012113390-0050	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.21	1.00 µg/L	11/24/2021 IC	11/26/2021 JW 14:51

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 581-6197
 Received: 11/22/2021 09:00 AM

Project: Brigantine Community School Lead In Water Testing

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
55-BE-218-S		11/20/2021 9:30:00 AM		012113390-0051	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.58	1.00 µg/L	11/24/2021 KB	11/24/2021 KB 13:36
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
56-BE-220(235)-S		11/20/2021 10:31:00 AM		012113390-0052	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 00:57
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
57-BE-217(219)-S		11/20/2021 10:33:00 AM		012113390-0053	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/24/2021 KB	11/24/2021 KB 13:40
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
58-BE-218(220)-S		11/20/2021 10:35:00 AM		012113390-0054	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.73	1.00 µg/L	11/24/2021 KB	11/24/2021 KB 13:42
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
59-BE-219(2215)-S		11/20/2021 10:40:00 AM		012113390-0055	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 00:59

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantine Community School Lead in Water Testing**

Analytical Results

Client Sample Description 60-BE-220(222)-S *Collected:* 11/20/2021 10:41:00 AM *Lab ID:* 012113390-0056

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.25	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 01:00

Client Sample Description 61-BE-221(223)-S *Collected:* 11/20/2021 10:42:00 AM *Lab ID:* 012113390-0057

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.80	1.00 µg/L	11/24/2021 KB	11/24/2021 KB 13:43

Client Sample Description 62-BE-222(224)-S *Collected:* 11/20/2021 10:45:00 AM *Lab ID:* 012113390-0058

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.83	1.00 µg/L	11/24/2021 KB	11/24/2021 KB 13:45

Client Sample Description 63-BE-223(225)-S *Collected:* 11/20/2021 10:46:00 AM *Lab ID:* 012113390-0059

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.27	1.00 µg/L	11/23/2021 KB	11/24/2021 KB 01:04

Client Sample Description 64-BE-HALL223L-DF *Collected:* 11/20/2021 10:47:00 AM *Lab ID:* 012113390-0060

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/24/2021 KB	11/24/2021 KB 14:21

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantine Community School Lead In Water Testing**

Analytical Results

Client Sample Description 65-BE-HALL223R-DF **Collected:** 11/20/2021 10:48:00 AM **Lab ID:** 012113390-0061

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/24/2021 KB	11/24/2021 KB 14:23

Client Sample Description 66-BE-224L-DF **Collected:** 11/20/2021 10:49:00 AM **Lab ID:** 012113390-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.76	1.00 µg/L	11/24/2021 KB	11/24/2021 KB 14:24

Client Sample Description 67-BE-224C-S **Collected:** 11/20/2021 10:50:00 AM **Lab ID:** 012113390-0063

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.82	1.00 µg/L	11/24/2021 KB	11/24/2021 KB 14:26

Client Sample Description 68-BE-224R-S **Collected:** 11/20/2021 10:51:00 AM **Lab ID:** 012113390-0064

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.41	1.00 µg/L	11/24/2021 KB	11/24/2021 KB 14:27

Client Sample Description 69-BE-224TEACH-S **Collected:** 11/20/2021 10:52:00 AM **Lab ID:** 012113390-0065

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.91	1.00 µg/L	11/24/2021 IC	11/26/2021 JW 17:07

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113390
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: Brigantine Community School Lead in Water Testing

Analytical Results

Client Sample Description 73-BE_BE-212(214)L-BL *Collected:* 11/20/2021 10:55:00 AM *Lab ID:* 012113390-0066

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/24/2021 KB	11/24/2021 KB 14:29

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Marylee Morinelli
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

12/13/2021

Phone: (609) 820-9312

Fax: (609) 561-6197

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/22/2021. The results are tabulated on the attached data pages for the following client designated project:

Brigantine Community School Lead in Water Testing

The reference number for these samples is EMSL Order #012113432. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

Report amended 12/13/2021 16:23:17 Replaces initial report from 12/03/2021 14:12:53 Report was merged with Order ID 012113390 per client request, and project name revised to Brigantine Community School Lead in Water Testing.

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113432
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantine Community School Lead in Water Testing**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
1-BM-Kitchen-POE		11/20/2021 11:00:00 AM		012113432-0001			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/29/2021	KB	11/29/2021	KB 23:51
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
2-BM-Kitchen-K		11/20/2021 11:01:00 AM		012113432-0002			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	5.00	1.00 µg/L	11/29/2021	KB	11/29/2021	KB 23:55
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
4-BM-KitchenR-S		11/20/2021 11:04:00 AM		012113432-0003			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/29/2021	KB	11/29/2021	KB 23:57
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
5-BM-KitchenL-S		11/20/2021 11:05:00 AM		012113432-0004			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	11/29/2021	KB	11/30/2021	KB 00:01
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
6-BM-B12(363)-S		11/20/2021 11:07:00 AM		012113432-0005			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.06	1.00 µg/L	11/29/2021	KB	11/30/2021	KB 00:03

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113432
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: Brigantine Community School Lead In Water Testing

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
9-BM-Foyer-BF		11/20/2021 11:08:00 AM		012113432-0006	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:04
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
10-BM-B5-S		11/20/2021 11:10:00 AM		012113432-0007	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:06
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
13-BM-B19(331)-S		11/20/2021 11:12:00 AM		012113432-0008	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:07
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
14-BM-BA-S		11/20/2021 11:13:00 AM		012113432-0009	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:09
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
15-BM-B21(329)-S		11/20/2021 11:15:00 AM		012113432-0010	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	4.75	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:10

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113432
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantine Community School Lead in Water Testing**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
16-BM-B22(324)-S		11/20/2021 11:17:00 AM		012113432-0011	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:11
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
17-BM-Super-S		11/20/2021 11:19:00 AM		012113432-0012	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	6.04	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:19
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
18-BM-A7(439)L-S		11/20/2021 11:21:00 AM		012113432-0013	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.03	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:20
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
19-BM-A7(439)C-S		11/20/2021 11:23:00 AM		012113432-0014	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.41	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:22
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
20-BM-A7(439)R-S		11/20/2021 11:27:00 AM		012113432-0015	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.55	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:23

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113432
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantline Community School Lead in Water Testing**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
23-BM-A2((343)-S		11/20/2021 11:31:00 AM		012113432-0016	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:25
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
24-BM-A3((344)-S		11/20/2021 11:32:00 AM		012113432-0017	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	4.01	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:26
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
29-BM-C15((417)-S		11/20/2021 11:35:00 AM		012113432-0018	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	5.02	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:28
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
30-BM-C25((414)-S		11/20/2021 11:37:00 AM		012113432-0019	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.46	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:29
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
32-BM-M0-S		11/20/2021 11:40:00 AM		012113432-0020	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:31

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113432
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantine Community School Lead in Water Testing**

Analytical Results

Client Sample Description 33-BM-PRIN-S *Collected:* 11/20/2021 11:42:00 AM *Lab ID:* 012113432-0021

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.13	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:39

Client Sample Description 34-BM-B27(321)-S *Collected:* 11/20/2021 11:43:00 AM *Lab ID:* 012113432-0022

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:44

Client Sample Description 35A-BM-D4(409)-S *Collected:* 11/20/2021 11:47:00 AM *Lab ID:* 012113432-0023

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	12.2	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:45

Client Sample Description 39-BM-D12(401)-S *Collected:* 11/20/2021 11:48:00 AM *Lab ID:* 012113432-0024

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.67	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:47

Client Sample Description 40-BM-D11(402)-S *Collected:* 11/20/2021 11:50:00 AM *Lab ID:* 012113432-0025

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	11.2	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012113432
CustomerID:	COAS80
CustomerPO:	
ProjectID:	

Attn: Marylee Morinelli Coastal Environmental Compliance, LLC PO Box 167 Hammonton, NJ 08037-0167	Phone: (609) 820-9312 Fax: (609) 561-6197 Received: 11/22/2021 09:00 AM
Project: Brigantine Community School Lead in Water Testing	

Analytical Results

<i>Client Sample Description</i> 41-BM-D6-S	<i>Collected:</i> 11/20/2021 11:51:00 AM	<i>Lab ID:</i> 012113432-0026
---	---	-------------------------------

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	9.80	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:50

<i>Client Sample Description</i> 42-BM-D7(406)-S	<i>Collected:</i> 11/20/2021 11:53:00 AM	<i>Lab ID:</i> 012113432-0027
--	---	-------------------------------

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	46.6	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:54

<i>Client Sample Description</i> 43-BM-D8(407)-S	<i>Collected:</i> 11/20/2021 11:55:00 AM	<i>Lab ID:</i> 012113432-0028
--	---	-------------------------------

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	5.84	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:56

<i>Client Sample Description</i> 44-BM-D10(463)-S	<i>Collected:</i> 11/20/2021 12:00:00 PM	<i>Lab ID:</i> 012113432-0029
---	---	-------------------------------

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	5.15	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:57

<i>Client Sample Description</i> 45-BM-D9(404)-S	<i>Collected:</i> 11/20/2021 12:02:00 PM	<i>Lab ID:</i> 012113432-0030
--	---	-------------------------------

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	27.5	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 00:58

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113432
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantine Community School Lead in Water Testing**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
46-BM-D14(313)-S		11/20/2021 12:04:00 PM		012113432-0031	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	20.9	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 01:00
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
46NA-BM-313-S		11/20/2021 12:06:00 PM		012113432-0032	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	10.7	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 01:04
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
46ND-BM-313-S		11/20/2021 12:08:00 PM		012113432-0033	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	4.22	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 01:06
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
49-BM-E1(312)-S		11/20/2021 12:10:00 PM		012113432-0034	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	15.7	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 01:07
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
50-BM-E2(311)-S		11/20/2021 12:12:00 PM		012113432-0035	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.73	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 01:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113432
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantine Community School Lead in Water Testing**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
51-BM-E3(309)-S		11/20/2021 12:13:00 PM		012113432-0036	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.69	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 01:13
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
52-BM-HallE3-S		11/20/2021 12:14:00 PM		012113432-0037	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 01:15
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
53-BM-E4(310)-S		11/20/2021 12:15:00 PM		012113432-0038	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 01:16
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
54-BM-E5(308)-S		11/20/2021 12:17:00 PM		012113432-0039	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.83	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 01:18
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
56-BM-E7(303)-S		11/20/2021 12:18:00 PM		012113432-0040	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/30/2021 KB 01:19

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012113432
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Marylee Morinelli**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 11/22/2021 09:00 AM

Project: **Brigantline Community School Lead in Water Testing**

Analytical Results

Client Sample Description 57-BM-E8(305)-S *Collected:* 11/20/2021 12:20:00 PM *Lab ID:* 012113432-0041

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/29/2021 KB 23:01

Client Sample Description 58-BM-E9(302)-S *Collected:* 11/20/2021 12:22:00 PM *Lab ID:* 012113432-0042

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.40	1.00 µg/L	11/29/2021 KB	11/29/2021 KB 23:08

Client Sample Description 59-BM-E10(301)-S *Collected:* 11/20/2021 12:25:00 PM *Lab ID:* 012113432-0043

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/29/2021 KB 23:10

Client Sample Description Blank *Collected:* *Lab ID:* 012113432-0044

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/29/2021 KB	11/29/2021 KB 23:11

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results